

**Sweetwater Springs  
Water District**  
17081 Hwy. 116, Ste. B  
P.O. Box 48  
Guerneville, CA 95446  
Tel (707) 869-4000  
Fax (707) 869-4005  
E-mail [sws@monitor.net](mailto:sws@monitor.net)  
Website: [www.sweetwatersprings.com](http://www.sweetwatersprings.com)

# Sweetwater Springs Water District 2019 Consumer Confidence Report Guerneville

**Board of Directors**

Rich Holmer, Pres.  
Larry Spillane  
Gaylord Schaap  
Tim Lipinski  
Sukey Robb-Wilder

*Monthly Board meetings are held the first Thursday of every month*

**Contact Person: Jack Bushgen, Field Manager**

Dear Sweetwater Springs Customer:

Water quality is an important issue with us. Providing water that meets state and federal drinking water standards is our Number 1 priority. The District provides water quality information each year to customers in conformance with these state and federal regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2019.

The District's water is supplied by three groundwater wells (#4, #5, #6) located between Rio Nido and Guerneville. A source water assessment was completed for all the wells in April of 2005. These sources are considered most vulnerable to historic gas stations not associated with any detected contaminants. You can obtain a summary of the assessment at our office at 17081 Hwy. 116, Ste. B, Guerneville.

**Este informe contiene información muy importante sobre su agua beber. Tradúzcalo ó hable con alguien que lo entienda bien.**

**The sources of drinking water** (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

**Contaminants that may be present in source water include:**

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.
- *Radioactive contaminants*, which can be naturally-occurring or be the result of oil and gas production and mining activities.

**In order to ensure that tap water is safe to drink**, USEPA and the state Department of Health Services (Department) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. Department regulations also establish limits for contaminants in bottled water that must provide the same protection for public health.

**Tables 1, 2, 3, 4, 5, and 6 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent.** The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The Department requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. Some of the data, though representative of the water quality, are more than one year old.

**TABLE 1 - SAMPLING RESULTS SHOWING THE DETECTION OF COLIFORM BACTERIA**

Microbiological Contaminants (to be completed only if there was a detection of bacteria)	Highest No. of detections	No. of months in violation	MCL	MCLG	Typical Source of Bacteria
Total Coliform Bacteria 2019	(In a mo.) 0	0	More than 1 sample in a month with a detection	0	Naturally present in the environment
Fecal Coliform or <i>E. coli</i> 2019	(In the year) 0	0	A routine sample and a repeat sample detect total coliform and either sample also detects fecal coliform or <i>E. coli</i>	0	Human and animal fecal waste

**TABLE 2 - SAMPLING RESULTS SHOWING THE DETECTION OF LEAD AND COPPER**

Lead and Copper (to be completed only if there was a detection of lead or copper in the last sample set)	No. of samples collected	90 <sup>th</sup> percentile level detected	No. Sites exceeding AL	AL	MCLG	Typical Source of Contaminant
Lead (ppb) 2019	23	<5.0	0	15	0.2	Internal corrosion of household water plumbing systems; discharges from industrial manufacturers; erosion of natural deposits.
Copper (ppm) 2019	23	1.02	0	1.3	0.3	Internal corrosion of household water plumbing systems; erosion of natural deposits; leaching from wood preservatives.

**TABLE 3 - SAMPLING RESULTS FOR SODIUM AND HARDNESS**

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant
Sodium (ppm)	2019	9.6	9.6	none	none	Generally found in ground and surface water
Hardness (ppm)	2019	160	160	none	none	Generally found in ground and surface water

**TABLE 4 - DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD**

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant
Gross Alpha (Radioactive) (Pc/L)	2013	0.69	0.69	15	N/A (0)	Erosion of natural deposits
Asbestos (MFL)	2018	ND	ND	7	7	Interior corrosion of asbestos mains; erosion of natural deposits
Barium (ppb)	2013	100	100	1000	N/A (2)	Discharge of oil drilling wastes and from metal refineries; erosion of natural deposits
Fluoride (ppm)	2013	0.26	0.26	2	N/A (1)	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
Arsenic (ppb)	2019	ND	ND	10	0.004	Erosion of natural deposits: Runoff from orchards, glass and electronics production wastes
Nitrate (as N)(ppm)	2019	Avg. 0.53	0.4-0.8	10	N/A (10)	Runoff and leaching from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
<b>DISINFECTION BYPRODUCTS, DISINFECTANT RESIDUALS AND DISINFECTION BYPRODUCT AND PRECURSORS IN DISTRIBUTION SYSTEM</b>						
Total Trihalomethanes (PPB)	2019	16	16	80	N/A (N/A)	Byproduct of drinking water chlorination
Total Haloacetic Acids (PPB)	2019	4.1	4.1	60	N/A	Byproduct of drinking water chlorination
Chlorine (PPM)	Daily 2019	Avg. 1.2	1.0-1.4	4	4	Drinking water disinfectant added for treatment

**TABLE 5 - DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD**

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant
Iron (ppb)	2019	ND (after treatment)	ND (after treatment)	300	N/A (N/A)	Leaching from natural deposits; industrial wastes
Manganese (ppb)	2019	ND (after treatment)	ND (after treatment)	50	N/A (N/A)	Leaching from natural deposits
Color (units)	2019	5	5	15	N/A (N/A)	Naturally occurring organic materials
Turbidity (units)	2019	Avg. 0.03 (before treatment)	0.01-0.4 (before treatment)	5	N/A (N/A)	Soil runoff
Total Dissolved Solids (TDS) (ppm)	2019	210	210	1000	N/A (N/A)	Runoff/leaching from natural deposits
Specific Conductance (micromhos)	2019	350	350	1600	N/A (N/A)	Substances that form ions when in water; seawater influence
Chloride (ppm)	2019	8.5	8.5	500	N/A (N/A)	Runoff/leaching from natural deposits; seawater influence
Sulfate (ppm)	2019	8.8	8.8	500	N/A (N/A)	Runoff/leaching from natural deposits' industrial wastes

**TABLE 6 - DETECTION OF UNREGULATED CONTAMINANTS**

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	Action Level (AL)	Health Effects Language
Boron (ppb)	2003	263	210-330	1000	Some men who drink water containing Boron in excess of the action level over many years may experience reproductive effects, based on studies in dogs

**Additional General Information On Drinking Water**

All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

**TERMS USED IN THIS REPORT:**

**Maximum Contaminant Level (MCL):** The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

**Primary Drinking Water Standards (PDWS):** MCLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

**Secondary Drinking Water Standards (SDWS):** MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

**ND:** not detectable at testing limit

**ppm:** parts per million or milligrams per liter (mg/L)

**ppb:** parts per billion or micrograms per liter (ug/L)

**pCi/L:** picocuries per liter (a measure of radiation)

**MFL:** million fibers per liter

**Public Health Goal (PHG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

**Maximum Contaminant Level Goal (MCLG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).

**Treatment Technique (TT):** A required process intended to reduce the level of a contaminant in drinking water.

**Regulatory Action Level (AL):** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

**Variations and Exemptions:** Department permission to exceed an MCL or not comply with a treatment technique under certain conditions.